

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16642

1. OWNER Wolfgang Lettow ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 5951 2901 S. Bannavitch St.
Pahrump, NV 89041 Pahrump, NV
 2. LOCATION SW 1/4 SW 1/4 Sec. 25 T. 20S N/S R. 53E E. Nye County
 PERMIT NO. 28-562-01 28-562-01 Pahrump City, Block 9, Lots 8-13
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Brown clay		4	8	4
White clay		8	30	22
Semi-cemented caliche		30	38	8
Brown clay		38	48	10
White clay	X	48	94	46
Brown clay	X	94	102	8
White clay	X	102	122	20
Brown clay	X	122	140	28

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	17#	.188	0	140

Perforations:
 Type perforation Torch cut
 Size perforation 1/2" wide, 8" long
 From 1.00 feet to 1.40 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 44 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started June 18, 1997.
 Date completed June 20, 1997.

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>20</u>	<u>0</u>	<u>15 min</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Charles Nyberg Well Drilling
 Address 1060 W. Basin Rd.
Paj Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 7484
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
 Signed Charles Nyberg
 By driller performing actual drilling on site or contractor
 Date June 30, 1997.

