

OFFICE USE ONLY
 Log No. 616619
 Permit No. 62935-T
 Basin. 216

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16233

1. OWNER SILVER STATE DISPOSAL ADDRESS AT WELL LOCATION APEX LAND FILL
 MAILING ADDRESS _____
 2. LOCATION NE 1/4 NW 1/4 Sec. 20 T 18 N34R 64 E CLARK County
 PERMIT NO. 62935TW2075 540-290-030 Subdivision Name _____
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY & GRAVEL		0	20	20
SANDSTONE WITH LIMESTONE STREAKS		20	450	430
CEMENTED GRAVEL		450	500	50
LIMESTONE		500	520	20
CEMENTED GRAVEL		520	585	65
LAYERS LIMESTONE & CEMENTED GRAVEL	X	585	670	85
LIMESTONE	X	670	750	80
CEMENTED GRAVEL	X	750	850	100
LIMESTONE	X	850	940	90

8. WELL CONSTRUCTION
 Depth Drilled 940 Feet Depth Cased 940 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 940
12 1/4 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.92	.188	+1	940

Perforations:
 Type perforation SAW
 Size perforation 1/8 X 3 8 ROW
 From 640 feet to 660 feet
 From 680 feet to 700 feet
 From 720 feet to 740 feet
 From 760 feet to 780 feet
 From 800 feet to 920 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 940 feet

9. WATER LEVEL
 Static water level: 610 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WATER WELL SERVICES Contractor
 Address 6475 GARY AVE. Contractor
LAS VEGAS, NV 89139
 Nevada contractor's license number 22311
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1594
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6-23-97



Date started 6-2, 19 97
 Date completed 6-21, 19 97

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			