WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 666621
Permit No. 62544
Basin 212

NOTICE OF INTENT NO. 16858

1. OWNER Hiten, Inc.
MAILING ADDRESS 1921 Stonehaven Drive
Las Vegas, NV 89108

ADDRESS AT WELL LOCATION 7227 Hauk

2. LOCATION SE ¼ SE ¼ Sec. 1 T. 22 N/S R. 60 E. Clark County
PERMIT NO. 62544 Issued by Water Resources | 176-01-801-017 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
Commercial
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Caliche		0	40	40
Sand & gravel, boulders		40	51	11
Sand & gravel, boulders & some clay		51	120	69
Whitish clay		120	140	20
Tan clay, some cobbles		140	256	116
Hard rock		256	263	7
Tan clay		263	330	67
Cemented sand & gravel		330	440	110
Cemented sand & gravel with layers of brown clay		440	540	100
Fine sand & cobbles		540	560	20
Cemented sand & gravel		560	592	32

Date started June 9, 19 97
Date completed June 19, 19 97

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 592 Feet Depth Cased 592 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼	Inches	0 Feet	592 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8		.188	+1	592

Perforations:
Type perforation mill slots
Size perforation 1/8 x 2½
From 392 feet to 532 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 592 feet

9. WATER LEVEL
Static water level 310 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Thompson Drilling Co., Inc. Contractor
Address 4185 West Harmon Contractor
Las Vegas, NV 89109

Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 856
Signed Richard K. Thompson
By driller performing actual drilling on site or contractor
Date June 19, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627