

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 1.6640

1. OWNER Joseph & Michele Grosco ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2601 N. Balzar St 2601 No. Balzar St.
Pahrump, NV 89048 Pahrump, NV 89048
 2. LOCATION SE 1/4 NE 1/4 Sec. 35 T. 19S N/S R. 52E E NYE County _____
 PERMIT NO. 28-901-01 28-901-01 Old Spanish Trails
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other _____ Municipal/Industrial Monitor Stock Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Soft Grey Clay		4	12	8
Brown clay		12	42	30
Clay w/gravel		42	55	13
Large rocks & clay	X	55	92	37
Hard cemented gravel		92	105	13
Clay w/gravel		105	122	17
Large rocks & sand	X	122	134	12
Cemented streaks & large gravel	X	134	160	26

8. WELL CONSTRUCTION
 Depth Drilled 1.60 Feet Depth Cased 1.60 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
1.2 Inches 0 Feet 1.60 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	17.4	.188	0	160

Perforations:
 Type perforation Torch cut
 Size perforation 1/4" wide, 8" long
 From 1.20 feet to 1.60 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 5.0' Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 5.0 feet to 1.60 feet

9. WATER LEVEL
 Static water level: 5.3 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 6-11-97, 19____
 Date completed 6-15-97, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>0</u>	<u>15 min</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Charles Nyberg Contractor
 Address 1060 W. Basin Rd. Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board: 7484
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 725
 Signed Charles Nyberg
 By driller performing actual drilling on site or contractor
 Date 6-23-97