WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66623
Permit No.
Basin 162

NOTICE OF INTENT NO. 16641

1. OWNER Kay Adams
MAILING ADDRESS 4140 W. Retread Rd.
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
4140 W. Retread Rd.
Pahrump, NV 89048

2. LOCATION NE ¼ SE ¼ Sec. 14 T. 20S N/S R. 52E E. Nye County
PERMIT NO. 28-731-21 (Issued by Water Resources) | 28-731-21 (Parcel No.) | Charleston Park Unit 3, Lot 30 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Grey clay		4	26	22
Brown clay		26	48	22
Soft gray clay	X	48	86	38
Soft brown clay	X	86	118	32
Grey clay		118	134	16
Brown clay		134	140	6

Date started 6-17-97, 19
Date completed 6-18-97, 19

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	-0-	15 min

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	17#	.188	0	140

Perforations:
Type perforation Torch cut
Size perforation ½" wide. 8" long
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg (Contractor)
Address 1060 W. Basin Rd. (Contractor)
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed (By driller performing actual drilling on site or contractor)
Date 6-23-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627