WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66650
Permit No.
Basin 179

NOTICE OF INTENT NO. 30852

1. OWNER Timothy Keogh
MAILING ADDRESS Po Box 150 631
East E. NV 89315

ADDRESS AT WELL LOCATION
Lot 59 48 st and Pole Line Rd

2. LOCATION SW ¼ SW ¼ Sec. 15 T. 17 N/S R. 63 E. White Pine County
PERMIT NO. N/A (Issued by Water Resources) 5-571-45 (Parcel No.) Cross timbers (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy top Soil		0	5	
gravel-cobble con.		5	13	
clay-gravel conglomerate		13	24	
Clay con.		24	29	
gravel clay con		29	47	
clay con		47	55	
gravel clay con		55	95	
gravel	water	95	96	
Clay gravel con		96	106	
gravel con	water	106	113	
clay		113	117	
gravel con	water	117	120	
clay con		120	136	
gravel con	water	136	141	
clay con		141	148	
gravel con	wata	148	152	
clay con		152	155	
Conglomerate con.				

RECEIVED 96 NOV 18 AM 10:50 STATE ENGINEERS OFFICE

Date started Oct 23, 1996
Date completed Nov 13, 1996

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	6	1 hr

8. WELL CONSTRUCTION
Depth Drilled 155 Feet Depth Cased 155 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 Inches		50 Feet	155 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	-1	155

Perforations:
Type perforation mill
Size perforation 5/8 x 2.5" x 6 row
From feet to feet
From feet to feet
From 113 feet to 155 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 155 feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name NATHAN R MAYNARD (Contractor)
Address Po Box 176 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0022869
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556

Signed Aaron Maynard (By driller performing actual drilling on site or contractor)
Date Nov 15-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627