


STATE OF NEVADA
 DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 66652
 Permit No. _____
 Basin _____



NOTICE OF INTENT NO. _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER BILL DAVIS
 MAILING ADDRESS 4375 SHECKLER ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION 60 SHADY CIRCLE

2. LOCATION NW 1/4 NW 1/4 Sec. 19 T 19 N/S R 29 E CHURCHILL County

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN SAND		0	20	20
BROWN CLAY		20	24	4
BROWN SAND		24	30	6
GREY SAND		30	50	20
BLACK SILT		50	70	20
GREY SILT / CLAY		70	80	10
GREY SAND		80	85	5
GREY CLAY		85	88	3
BROWN SAND	X	88	98	10

8. WELL CONSTRUCTION
 Depth Drilled 98 Feet Depth Cased 98 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 1/4 Inches 0 Feet 50 Feet
6 1/4 Inches 50 Feet 98 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	98

Perforations:
 Type perforation MACHINE SLOT
 Size perforation .080

From 91 feet to 96 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 FT Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 21.9 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality UNTESTED

Date started 5/15/96 _____ 19_____
 Date completed 5/15/96 _____ 19_____

7. WELL TEST DATA

TEST METHOD:		<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)		
<u>20</u>		<u>1 hr.</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Drilling Corp. Contractor
 Address P. O. BOX 888 Contractor
FALLON, NV 89407

Nevada contractor's license number issued by the State Contractor's Board 11752

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996

Signed Matt Sullivan for J. Driffler
 By driller performing actual drilling on-site or contractor
 Date 6-4-96