X

WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66664
Permit No.
Basin 247

NOTICE OF INTENT NO. 00384

1. OWNER ORVAL & CHARYLE SNOWDEN
MAILING ADDRESS P.O. BOX 1157
ELKO, NV 98903

ADDRESS AT WELL LOCATION
SE CORNER OF E. MEADOW VIEW DR. AND NO. MEADOW V.

2. LOCATION SE 1/4 SE 1/4 Sec. 35 T 33N N/S R 55E E ELKO County
PERMIT NO. _____ Issued by Water Resources
77-06-09 Parcel No.
WESTERN HILLS Subdivision Name

**3. WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

**4. PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

**5. WELL TYPE**
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other _____

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| TOPSOIL | | 0 | 1 | 1 |
| BROWN SANDY CLAY | | 1 | 20 | 19 |
| BROWN SILTSTONE | X | 20 | 120 | 100 |

Date started 10/31/96, 19__
Date completed 10/31/96, 19__

**7. WELL TEST DATA**

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 40 | | 2 |

**8. WELL CONSTRUCTION**
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 10 5/8 | Inches | 0 | Feet | 120 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13 | .188 | +1 | 120 |

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 100 feet to 120 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 120 feet

**9. WATER LEVEL**
Static water level 18 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1998

Signed Bradley D. Wiest
By driller performing actual drilling on-site or contractor

Date 11-12-96