WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66676
Permit No.
Basin 076 T

NOTICE OF INTENT NO. 34975

1. OWNER Ether Westmoreland
MAILING ADDRESS PO Box 2550
Winnemucca, NV 89446

ADDRESS AT WELL LOCATION 3135 Ether Way
Ether Way Wmca, NV 89445

2. LOCATION NW 1/4 ____ 1/4 Sec. 24 T 35N N/S R 37E E Humboldt County
PERMIT NO. ____ Issued by Water Resources | F-3 Parcel No. | Westmoreland Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other ____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other ____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	6	6
Gravel		6	65	59
Clay		65	73	8
Cobbles & gravel		73	164	91

Date started 10/16/96, 19__
Date completed 10/17/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		2

8. WELL CONSTRUCTION
Depth Drilled 164 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	50	Feet
9 7/8	Inches	50	Feet	164	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	160

Perforations:
Type perforation Single row mill slot
Size perforation 1/8 X 3
From 120 feet to 160 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 160 feet

9. WATER LEVEL
Static water level 121 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc.
Contractor
Address 4675 West Winnemucca Blvd.
Contractor
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2019

Signed ____
By driller performing actual drilling on-site or contractor

Date 11-12-96