WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66712
Permit No.
Basin 162

NOTICE OF INTENT NO. 15543

1. OWNER Rod and Alice Rodowick
MAILING ADDRESS 4151 E. England
Pahrump, NV 89048

ADDRESS AT WELL LOCATION 4151 E. England

2. LOCATION SW 1/4 SW 1/4 Sec. 32 T 20S N/S R 54E E Nye County
PERMIT NO. _____ Issued by Water Resources | 27-471-32 Parcel No. | n/a Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Silty Loam		0	10	10
Grey Calache		10	18	8
Brown Calache		18	25	7
Brown Clay		25	45	20
Grey Clache		45	55	10
Grey Calache		55	62	7
Cream Clay	x	62	87	25
Light Brown Clay	x	87	112	25
Brown Clay	x	112	131	19
White Clay	x	131	153	22
Tan Clay	x	153	165	12

Date started 6/26/97, 19__
Date completed 6/28/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	n/a	.50

8. WELL CONSTRUCTION
Depth Drilled 165 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 3/4 Inches		0 Feet	165 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	160

Perforations:
Type perforation Saw-Cut
Size perforation .25x6
From 115 feet to 160 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 165 feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. (Contractor)
Address 2301 Winery Road, Suite 2 (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2025
Signed Gary Strickland (By driller performing actual drilling on-site or contractor)
Date 07-09-97

Received JUL 14 1997