WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66713
Permit No.
Basin 162

NOTICE OF INTENT NO. 15540

1. OWNER Rod and Alice Rodowick
MAILING ADDRESS 4211 E. England
Pahrump, NV 89041

ADDRESS AT WELL LOCATION 4211 E. England

2. LOCATION SW 1/4 SW 1/4 Sec. 32 T 20S N/S R 54E E Nye County
PERMIT NO. (Issued by Water Resources) | Parcel No. 27-471-31 | Subdivision Name n/a

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Loam		0	8	8
Grey Calache		8	18	10
Brown Clay		18	37	19
Gravel		37	40	34
Brown Clay		40	70	30
Cream Claya		70	121	51
White Clay	x	121	156	35
Tan Clay	x	156	165	9

Date started 6/30/97, 19__
Date completed 7/2/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	n/a	.50

8. WELL CONSTRUCTION
Depth Drilled 165 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 3/4 Inches		0 Feet	165 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	160

Perforations:
Type perforation Saw-cut
Size perforation .25x6
From 125 feet to 165 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 165 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. (Contractor)
Address 2301 Winery Road, Suite 2 (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2025
Signed (By driller performing actual drilling on-site or contractor)
Date 07-09-97

JUL 14 1997