

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 66725
 Permit No. 212
 Basin 212



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16816

1. OWNER LUP ADDRESS AT WELL LOCATION Off Russell
 MAILING ADDRESS 4420 S Decatur N. 22 S. N. R. Boes
LL 89103
 2. LOCATION SE 1/4 26 T 21 N 2 R 62 E Clark County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test Monitor Stock
 Municipal/Industrial Other _____
 5. WELL TYPE Cable Rotary RVC Air Other Bucket

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy Dirt</u>		<u>0</u>	<u>7</u>	<u>7</u>
<u>Sand + Gravel</u>		<u>7</u>	<u>9</u>	<u>2</u>
<u>Clay w/ Sand</u>		<u>9</u>	<u>17</u>	<u>8</u>
<u>Sand w/ gravel/boulders</u>		<u>17</u>	<u>21</u>	<u>4</u>
<u>Sandy Clay</u>		<u>21</u>	<u>25</u>	<u>4</u>
<u>Sand + Gravel</u>		<u>25</u>	<u>36</u>	<u>11</u>
<u>Consolidated Rock</u>		<u>36</u>	<u>40</u>	<u>4</u>
<u>Sandy, Silty Clay</u>		<u>40</u>	<u>70</u>	<u>30</u>

8. WELL CONSTRUCTION
 Depth Drilled 70 Feet Depth Cased 70 Feet
 HOLE DIAMETER (BIT SIZE)
 From 30 Inches To 37 Feet
24 Inches From 37 Feet To 70 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12</u>	<u>PUK</u>	<u>Sch 40</u>	<u>0</u>	<u>70</u>

Perforations:
 Type perforation Slot
 Size perforation .03270
 From 0 feet to 70 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 0 feet to 70 feet

9. WATER LEVEL
 Static water level 9 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 62.0 °F Quality Good

Date started 6-19, 1997
 Date completed 6-19, 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge
 Name GDC Contractor
 Address 536 E. Main St Contractor
Ontario CA
 Nevada contractor's license number 31246 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1968
 Signed _____
 By driller performing actual drilling on site or contractor
 Date 7-1-97