

OFFICE USE ONLY
Log No. 66127
Permit No. _____
Basin 061

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25582

1. OWNER BARRICK GOLDSTRIKE ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINE
MAILING ADDRESS P.O. BOX 29
ELKO, NV. 89801
2. LOCATION SE 1/4 NE 1/4 Sec 30 T 36 S R 50 F. EUREKA County
PERMIT NO. 61407 N/A Parcel No. N/A Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOPSOIL		0	11	11
BROWN CLAYS, SOME		11	80	69
ROCK				
RED CLAYS		80	100	20
BLACK-GREEN GRANITE		100	125	25
WEATHERED GRANITE		125	280	155
DIORITE-FRACTURES W/CLAY				
GRAY-GREEN DIORITE		280	335	55
CLAY ALTERED		335	375	40
GRAY-BLACK VINNINI		375	645	270
CLAY ALTERED		645	700	55
GRAY-BLACK BROKEN IN SPOTW WITH CLAYS		700	1220	520

8. WELL CONSTRUCTION
Depth Drilled 1220 Feet Depth Cased 1190 Feet
HOLE DIAMETER (BIT SIZE)
From To
20-1/2 Inches 0 Feet 35 Feet
14-3/4 inches 35 Feet 1220 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	62.55	.375	0	35
8.625	22.36	.250	+2	108

Perforations: LOUVERED SLOT
Type perforation
Size perforation .125
From 108 feet to 1190 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 103 FEET Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 108 feet to 1220 feet

9. WATER LEVEL
Static water level 635 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 70 °F Quality FAIR

Date started SEPTEMBER 19, 1996
Date completed OCTOBER 8, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
AIRLIFT	<u>< 100 GPM</u>		<u>190 HRS. TOTAL</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING Contractor
Address 2286 WEST 1500 SOUTH Contractor
SALT LAKE CITY, UTAH 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1773
Signed MARK WAITE By driller performing actual drilling on site or contractor
Date OCTOBER 30, 1996