



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16816

1. OWNER LVP ADDRESS AT WELL LOCATION OFF RUSSEL
 MAILING ADDRESS 4470 S Decatur N. Sam Boyd
 2. LOCATION 1/4 SE 1/4 Sec 26 T. 21 N. R. 62 E. Clark County
 PERMIT NO. DW 1069 Issued by Water Resources Parcel No. 161-267001-001 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE De-water WELL TYPE
 Domestic Irrigation Test Cable Rotary RVC
 Municipal/Industrial Monitor Stock Air Other Bucket

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy Silt</u>		<u>0</u>	<u>6</u>	<u>6</u>
<u>Clayd/Sand</u>		<u>6</u>	<u>7</u>	<u>1</u>
<u>Sand & Gravel</u>		<u>7</u>	<u>12</u>	<u>5</u>
<u>Sand w/ Boulders</u>		<u>12</u>	<u>19</u>	<u>7</u>
<u>Sandy Clay</u>		<u>19</u>	<u>26</u>	<u>7</u>
<u>Sandy Gravel</u>		<u>26</u>	<u>37</u>	<u>11</u>
<u>Conglomerate Rock</u>		<u>37</u>	<u>38</u>	<u>1</u>
<u>Coarse Gravel</u>		<u>38</u>	<u>39</u>	<u>1</u>
<u>Conglomerate Rock</u>		<u>39</u>	<u>41</u>	<u>2</u>
<u>Sandy Silty Clay</u>		<u>41</u>	<u>60</u>	<u>19</u>

8. WELL CONSTRUCTION
 Depth Drilled 60 Feet Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)
 From 30 Inches To 37 Feet
24 Inches 37 Feet 60 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12</u>	<u>PVC</u>	<u>5/16</u>	<u>0</u>	<u>60</u>

Perforations:
 Type perforation Spot
 Size perforation 0.035
 From 0 feet to 20 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to 60 feet

9. WATER LEVEL
 Static water level 9 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 76 °F Quality Good

Date started 6-25, 1997
 Date completed 6-25, 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GDC Contractor
 Address 536 E. Warland Contractor
Ontario CA

Nevada contractor's license number 31246
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1968

Signed _____
 By driller performing actual drilling on site or contractor
 Date 7-2-97

