WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66755
Permit No.
Basin 212

NOTICE OF INTENT NO. 8705

1. OWNER City of Henderson
MAILING ADDRESS 240 Water St Henderson NV 89015
ADDRESS AT WELL LOCATION Proposed Disposal Expansion Site

2. LOCATION SE ¼ SE ¼ Sec. 6 T. 22 X/S R. 63 E. Clark County
PERMIT NO. M/D 403 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG MW-2

Material	Water Strata	From	To	Thickness
GRAVELLY SAND - brn	N	0	35	35
SILTY CLAY - w/gypsum red brn	Y	35	47	12

RECEIVED
JUL 20 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 4/16, 1991
Date completed 4/16, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 47 Feet Depth Cased 47 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	17 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		sch 40 PVC	0	47

Perforations:
Type perforation slotted screen
Size perforation .020"
From 47 feet to 32 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 31
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 47 feet to 31 feet

9. WATER LEVEL
Static water level 33.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LST Environmental Consultants (Contractor)
Address 4085 Nevso Dr #6 (Contractor)
LV NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1761
Signed (By driller performing actual drilling on site or contractor)
Date 7-30-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627