WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66761
Permit No.
Basin 212

NOTICE OF INTENT NO. 8709

1. OWNER City of Henderson
MAILING ADDRESS 240 Water St
Henderson NV 89015

ADDRESS AT WELL LOCATION Proposed Disposal Expansion Site

2. LOCATION NW ¼ NE ¼ Sec. 7 T. 22 ~~N~~S R. 63 E. Clark County
PERMIT NO. M/O 403 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG MW-3

Material	Water Strata	From	To	Thickness
GRAVELLY SAND - brn	N	0	35	35
SANDY CLAY - red brn	Y	35	48.5	13.5

RECEIVED
JUL 20 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 4/17, 1991
Date completed 4/17, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 48.5 Feet Depth Cased 48.5 Feet

HOLE DIAMETER (BIT SIZE)
Inches From 0 Feet 48.5 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		sch 40 PVC	0	48.5

Perforations:
Type perforation slotted screen
Size perforation .020 inch
From 48.5 feet to 33.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 32.5
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 32.5 feet to 48.5 feet

9. WATER LEVEL
Static water level 36.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LJT Environmental Consultants (Contractor)
Address 4885 Nevso Dr #6 (Contractor)
LV NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1761
Signed (By driller performing actual drilling on site or contractor)
Date 4-30-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627