

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____

1. OWNER Bob Davis ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2554 Idaho ST #24 12 miles North of Elko on Hwy 225
Elko NV 89801
 2. LOCATION NE 1/4 NW 1/4 Sec 26 T 36 R 56 E Elko County _____
 PERMIT NO. _____ Parcel No. 05-530-13-4 Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Top Soil</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>Clay + large gravel</u>		<u>5</u>	<u>35</u>	<u>30</u>
<u>Clay Clay</u>		<u>35</u>	<u>65</u>	<u>30</u>
<u>Sandy clay</u>	<u>x</u>	<u>65</u>	<u>210</u>	<u>145</u>
<u>Sandstone</u>		<u>210</u>	<u>240</u>	<u>30</u>
<u>Sand with Clay Layers</u>		<u>240</u>	<u>320</u>	<u>80</u>

8. WELL CONSTRUCTION
 Depth Drilled 320 Feet Depth Cased 320 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
1.1 Inches 0 Feet 320 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>		<u>1.87</u>	<u>0</u>	<u>320</u>

Perforations:
 Type perforation Mill Slat
 Size perforation _____
 From 270 feet to 310 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 52 Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 52 feet to 320 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality _____

Date started 10-7 1996
 Date completed 10-10 1996

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AAA Drilling Co Contractor
 Address Box 2487 Contractor
Elko NV 89801
 Nevada contractor's license number issued by the State Contractor's Board 20684
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1783
 Signed Larry R. Chaffield
 By driller performing actual drilling on site or contractor
 Date 10-17-96