WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66813
Permit No.
Basin 167

NOTICE OF INTENT NO. 99 1 1

1. OWNER Bella Vista Partners c/o Goold Patterson, DeVore / Rondeau
MAILING ADDRESS 300 South 4th Street Suite 905
Las Vegas, Nevada 89101

ADDRESS AT WELL LOCATION West of Lot 11 on East side of Seville Way - See attached Plot Plan

2. LOCATION NW ¼ NW ¼ Sec 4 T 23 N/S R 64 E Clark County
PERMIT NO. MO-2533 Issued by Water Resources
(W-2) Parcel No.
Bella Vista Estates Boulder City Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FILL - Sandy Gravel		0	6	6
Gravelly Sand		6	7½	1½
Sandy Gravel		7½	10½	3
Sandy Clay		10½	20	9½

RECEIVED
JAN 25 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 1-14, 1995
Date completed 1-14, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NA		

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
7 7/8 Inches		0 Feet	20 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		sch 40 PVC		

Perforations:
Type perforation Factory Slots
Size perforation .010
From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 3
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 4 feet to 20 feet

9. WATER LEVEL
Static water level None feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature N/A °F Quality Water

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Terracon Consultants Western Contractor
Address 3711 Regulus Dr. Contractor
L.V., NV. 89102
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1944
Signed Thomas M. Beall By driller performing actual drilling on site or contractor
Date 1-19-95

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627