

OFFICE USE ONLY  
Log No. 6682  
Permit No. \_\_\_\_\_  
Basin 213



PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 141067

1. OWNER GOODFON ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS 5070 Anville Street SW - 7 CELIS MARKET LAUGHLIN, NV  
LU NV 89119

2. LOCATION SE 1/4 NW 1/4 Sec 13 T 32 N8R 66 E CLARK County  
PERMIT NO. MO-2438A Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Angel

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>fine sands</u>		<u>0</u>	<u>20</u>	
<u>clay</u>		<u>20</u>	<u>22</u>	
<u>fine sands</u>		<u>22</u>	<u>40</u>	
<u>gravel</u>		<u>40</u>	<u>41</u>	
<u>sands</u>		<u>41</u>	<u>43</u>	

8. WELL CONSTRUCTION  
Depth Drilled 43 Feet Depth Cased 43 Feet

HOLE DIAMETER (BIT SIZE)  
From \_\_\_\_\_ To \_\_\_\_\_  
7 Inches 0 Feet 43 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.5</u>	<u>PVC</u>	<u>sch 80</u>	<u>0</u>	<u>40</u>

Perforations:  
Type perforation slotted screen  
Size perforation 0.25  
From 40 feet to 43 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 36  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 38 feet to 43 feet

9. WATER LEVEL  
Static water level 24 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 2-23, 1995  
Date completed 2-23, 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Weber Environmental Contractor  
Address 4301 S. Valley View #21 Contractor  
LU NV 89103

Nevada contractor's license number issued by the State Contractor's Board 00 356 39  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1847

Signed \_\_\_\_\_  
By driller performing actual drilling on site or contractor  
Date 3-20-95

RECEIVED  
APR 3 1995  
Div. of Water Resources  
Branch Office - Las Vegas, NV