

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 466822
 Permit No. 213
 Basin. 213

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10546

1. OWNER The Planning Group; ADDRESS AT WELL LOCATION Riverside Hotel & Casino
 MAILING ADDRESS PO Box 69, Bullhead Laughlin NV
City AZ 86430
 2. LOCATION 1/4 NW 13 T. 32 N. S. R. 66 E Clark County
 PERMIT NO. MO-20954 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG MW-10

Material	Water Strata	From	To	Thickness
Fill - asphalt over base	N	0	1	1
SAND - w/ coarse gravel, brn	N	1	3	2
SILTY CLAY - brn	N	3	8.5	5.5
SILTY SAND - brn	N	8.5	11.5	3.0
SANDY CLAY - brn	N	11.5	14	2.5
SILTY CLAY - brn	N	14	22	8
CLAYEY SILT - brn	N	22	23	1
GRAVELLY SAND - brn	Y	23	30	7

8. WELL CONSTRUCTION
 Depth Drilled 30 Feet Depth Cased 30 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 30
8 Inches Feet
 Inches Feet
 Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>sch 40</u>	<u>MC</u>	<u>0</u>	<u>30</u>

Perforations:
 Type perforation .010" slotted screen
 Size perforation
 From 20 feet to 30 feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 18
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 18 feet to 30 feet

9. WATER LEVEL
 Static water level 22.0 feet below land surface
 Artesian flow - G.P.M. - P.S.I.
 Water temperature - °F Quality -

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Tim Atan - Western Technologies Inc Contractor
 Address 3611 W. Tompkins Ave Contractor
Las Vegas, NV 89107
 Nevada contractor's license number issued by the State Contractor's Board -
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M7761
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>2</u>	<u>1.5</u>	<u>0.16</u>

 Date started Oct 7, 1992
 Date completed Oct 7, 1992

RECEIVED
 OCT 21 1992
 Div. of Water Resources
 Branch Office - Las Vegas, NV