



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14067

1. OWNER GLADSON ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 5070 Anville St SU-7 Sec 13 T 32 N R 66 E CLARK LAUGHLIN, NV  
LV NV 89119

2. LOCATION SE 1/4 NW 1/4 Sec 13 T 32 N R 66 E CLARK County  
 PERMIT NO. NO-2438A Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>poorly graded sand</u>		<u>0</u>	<u>20</u>	
<u>clay</u>		<u>20</u>	<u>22</u>	
<u>poorly graded sand</u>		<u>22</u>	<u>40</u>	
<u>gravel</u>		<u>40</u>	<u>41</u>	
<u>sand</u>		<u>41</u>	<u>43</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 43 Feet Depth Cased 43 Feet

HOLE DIAMETER (BIT SIZE)  
 From 7 Inches To 4 3/4 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>7.5</u>	<u>N/C</u>	<u>sch 80</u>	<u>0</u>	<u>40</u>

Perforations:  
 Type perforation slotted screen  
 Size perforation 20  
 From 40 feet to 43 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 3.6  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 3.8 feet to 43 feet

9. WATER LEVEL  
 Static water level 2.7 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Weber Environmental Contractor  
 Address 4301 S Sally View #21 Contractor  
LV NV 89103  
 Nevada contractor's license number issued by the State Contractor's Board 00 35639  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1847  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date 3-20-95

Date started 3-1, 1995  
 Date completed 3-1, 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED  
 APR 3 1995  
 DIV. of Water Resources  
 Branch Office - Las Vegas, NV