WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66856
Permit No.
Basin 212

NOTICE OF INTENT NO. 13066

1. OWNER DAVE MASON C/O BROADBENT & ASSOC.
MAILING ADDRESS 833 NEVADA HWY STE 4
BOULDER CITY NV 89005

ADDRESS AT WELL LOCATION FORMER GAUDIN FORD SITE (NEAR 4th ST AND LAS VEGAS BLVD SO)

2. LOCATION NE 1/4 NW 1/4 Sec. 3 T. 21 N(S) R 61 E CLARK County
PERMIT NO. MO-2395B (Issued by Water Resources) 040-027-002 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE MW-8
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| ASPHALT/FILL | | 0 | 4½ | 4½ |
| SILTY CLAY | | 4½ | 20 | 15½ |

Date started MARCH 8, 1994
Date completed MARCH 8, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 8 Inches | | 0 Feet | 20 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2.375 | 0.64 | 0.154 | 0 | 20 |
| | | | | |

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-1/1-3 BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 3 feet to 20 feet

9. WATER LEVEL
Static water level 9.52 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMAS HIGH
Address 4670 SO. POLARIS AVE (Contractor)
LAS VEGAS NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869
Signed: By driller performing actual drilling on site or contractor
Date 3-30-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627