WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66858
Permit No.
Basin 212

NOTICE OF INTENT NO. 11362

1. OWNER HESMAT MOHAJERANI
MAILING ADDRESS 8729 DOUBLE EAGLE DR. LAS VEGAS NV
ADDRESS AT WELL LOCATION CHAPEL OF LOVE 1426 LAS VEGAS BLVD SOUTH

2. LOCATION SW ¼ NW ¼ Sec. 3 T. 21 N/S R. 61 E. CLARK County
PERMIT NO. M0-2227 Issued by Water Resources. Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE MW-5
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT & FILL		0	2	2
CLAY		2	5	3
CLAYEY SILT		5	7	2
CALICHE GRAVEL		7	9	2
CALICHE		9	11	2
SILTY SAND		11	11.5	0.5
SILTY CLAY		11.5	13	1.5
CLAYEY SILT		13	15	2
CALICHE		15	15.5	0.5
SANDY SILT		15.5	20	4.5

RECEIVED JAN 14 1994 Div. of Water Resources Eastern Office - Las Vegas, NV

Date started JANUARY 11, 1994
Date completed JANUARY 11, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	20 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
~~2.375~~	~~0.64~~	~~0.154~~	~~0~~	
4.5	1.9	0.237	0	20

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-2'/2-4' BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 4 feet to 20 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name TOM HIGH
Address 4670 SOUTH POLARIS AVE LAS VEGAS NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869
Signed (By driller performing actual drilling on site or contractor)
Date JANUARY 13, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627