WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66883 (in Book)
Permit No.
Basin 212

NOTICE OF INTENT NO. 10109

1. OWNER Nev. Div. of Environ. Protection
MAILING ADDRESS 555 E. Washington Ave #4300 Las Vegas 89101
ADDRESS AT WELL LOCATION American Coin 1901 Industrial Rd

2. LOCATION NW ¼ SW ¼ Sec. 4 T. 21 ☒ S R. 61 E. Clark County
PERMIT NO. MO-2535 Issued by Water Resources
162-04-706-004 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Augur

6. LITHOLOGIC LOG MW-2

Material	Water Strata	From	To	Thickness
Fill - Asphalt / base		0	1	1
SILTY CLAY		1	9	8
CALICHE lenses		9	11.5	2.5
SANDY CLAY w/ gravel	Y	11.5	14	2.5
CLAYEY SAND	Y	14	19	5
SILTY CLAY	Y	19	22.5	3.5

RECEIVED
FEB 10 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started JAN 19, 1995
Date completed JAN 19, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 22.5 Feet Depth Cased 21 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches		0 Feet	22.5 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	sch 40	0	21

Perforations:
Type perforation slotted screen
Size perforation 0.010"
From 6 feet to 21 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 6
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 6 feet to 22.5 feet

9. WATER LEVEL
Static water level 7.17 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Tim Aten c/o WTI Contractor
Address 3611 W. Tompkins Ave Contractor
Las Vegas 89103
Nevada contractor's license number — issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1761
Signed [signature] By driller performing actual drilling on site or contractor
Date 2-6-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627