WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 66907
Permit No.
Basin 212

MW-10

NOTICE OF INTENT NO. 9525

1. OWNER PAYLESS, INC
MAILING ADDRESS 9275 S.W. Pettan Lane
Wilsonville OR ~~9070~~ 97070

ADDRESS AT WELL LOCATION S.W. corner
Sahara Ave + Valley View BLVD
LAS VEGAS NV

2. LOCATION SE 1/4 SW 1/4 Sec. 6 T. 21 N/S R. 61 E. CLARK County

PERMIT NO. MO-2159 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGUR

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Fill, Sandy silt w/gravel | | 0 | 3 | 3 |
| Clayey Silt | | 3 | 6.5 | 3.5 |
| Silty clay | | 6.5 | 8.5 | 2.0 |
| CALICHE | | 8.5 | 13 | 4.5 |
| Sandy silt w/gravel | | 13 | 16 | 3.0 |
| Silty clay | | 16 | 22 | 6.0 |
| Sandy silt | | 22 | 25 | 3.0 |

RECEIVED
AUG 24 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 8-18-92, 1992
Date completed 8-18, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 8 Inches | 0 Feet | 25 Feet | |
| Inches | Feet | Feet | |
| Inches | Feet | Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 | 0.070 | SCH. 40 | 0 | 25 |
| | | | | |
| | | | | |

Perforations:
Type perforation Factory slotted
Size perforation 0.020
From 10 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 6
Placement Method: ☐ Pumped ☐ Poured

Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 8 feet to 25 feet

9. WATER LEVEL
Static water level 16.00 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Richard LeBlanc / Converse Consultants (Contractor)
Address 4670 S. Polaris Ave (Contractor)
LAS VEGAS NEV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1817
Signed (By driller performing actual drilling on site or contractor)
Date 8.24.92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627