

OFFICE USE ONLY
 Log No. 66935
 Permit No. _____
 Basin 203

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16435

1. OWNER Mong Courier ADDRESS AT WELL LOCATION 700' North of Intersection of Pam and Roswell Road
 MAILING ADDRESS Ac 31 Box 202 Sandy Valley NV 89019
 2. LOCATION S/W 1/4 N/E 1/4 Sec. 14 T. 3 N. R. 67 E. Lincoln County Mesdow Valley Estates
 PERMIT NO. 6 Issued by Water Resources Parcel No. 13-050-38 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	12	12
sand-boulders		12	23	11
clay-sand		23	90	67
gravel-sand	X	90	142	52
clay		142	146	4

8. WELL CONSTRUCTION
 Depth Drilled 146 Feet Depth Cased 146 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet
 To 146 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>0</u>	<u>.188</u>	<u>0</u>	<u>146</u>

Perforations:
 Type perforation factory
 Size perforation 1 3/8" x 3"
 From 106 feet to 146 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 146 feet

9. WATER LEVEL
 Static water level 67 feet below land surface
 Artesian flow _____ G.P.M. _____
 Water temperature 20.8 °F Quality good

Date started 7-7-97 19____
 Date completed 7-10-97 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>Bailer</u>	<u>28</u>	<u>9</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Davis Drilling - Pumps Contractor
 Address P.O. Box 59 Hiko NV 89012 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0028766
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1121
 Signed Mike Davis
 By driller performing actual drilling on site or contractor
 Date 7-17-97