

OFFICE USE ONLY  
 Permit No. 212-021  
 Basin 212-021

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16240

1. OWNER JIM LAMB ADDRESS AT WELL LOCATION HUALIPAI & HWY 160  
 MAILING ADDRESS 9451 S. HUALIPAI

2. LOCATION NE 1/4 SE 1/4 Sec. 24 T. 22 N/S R. 59 E. CLARK County  
 PERMIT NO. 175-24-701-002-97

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

| Material                              | Water Strata | From | To  | Thick-ness |
|---------------------------------------|--------------|------|-----|------------|
| SANDY CLAY WITH STRKS CEMENTED GRAVEL |              | 0    | 120 | 120        |
| CEMENTED GRAVEL SANDSTONE             |              | 120  | 375 | 255        |
| CEMENTED GRAVEL                       | X            | 375  | 495 | 120        |
| CEMENTED GRAVEL & SANDSTONE           | X            | 495  | 545 | 50         |
| LIMESTONE                             | X            | 545  | 680 | 125        |
|                                       |              | 680  | 700 | 20         |

8. WELL CONSTRUCTION  
 Depth Drilled 700 Feet Depth Cased 700 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 700 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 5 5/8              | 10.9                | .188                    | +1          | 700       |

Perforations: SAW  
 Type perforation  
 Size perforation 1/8 X 3 5 ROWS  
 From 580 feet to 600 feet  
 From 620 feet to 640 feet  
 From 660 feet to 680 feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 700 feet

9. WATER LEVEL  
 Static water level 478 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WATER WELL SERVICES Contractor  
 Address 6475 GARY AVE. Contractor  
LAS VEGAS, NV 89139

Nevada contractor's license number issued by the State Contractor's Board 22311  
 Nevada driller's license number issued by the Division of Water Resources 1594  
 the on-site driller

Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 7/14/97

Date started 7/2, 19 97  
 Date completed 7/10, 19 97

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
|        |                               |              |
|        |                               |              |
|        |                               |              |
|        |                               |              |



I