WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66929
Permit No. 61901
Basin 212

NOTICE OF INTENT NO. 16832

1. OWNER ~~Xoeoiaxoestoxx~~ Atlandia Design
MAILING ADDRESS 3260 Industrial Road
Las Vegas, NV 89109

ADDRESS AT WELL LOCATION Bellagio Hotel ~~#XXX~~ Well A

2. LOCATION SW ¼ NE ¼ Sec. 20 T. 21 N/S R. 61 E Clark County
PERMIT NO. 61901 Issued by Water Resources | 162-20-501-002 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation Recreation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
~~Type II fill~~		~~0~~	~~6~~	~~6~~
~~Tan sandy clay with caliche stringers~~		~~6~~	~~45~~	~~39~~
~~Brown sandy clay with small gravels~~		~~45~~	~~180~~	~~135~~
~~Brown sandy clay~~		~~180~~	~~220~~	~~40~~
~~Brown Sandy clay with small gravels stringers~~		~~220~~	~~680~~	~~460~~
~~Cemented sand & gravel~~		~~680~~	~~710~~	~~30~~
~~Brown sandy clay & small gravels~~		~~710~~	~~1080~~	~~370~~

JUL 29 1997

Date started 4-21- , 19 97
Date completed 7-16 , 19 97

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100	127	2 hours
200	151	2 hours
300	184	2 hours

8. WELL CONSTRUCTION
Depth Drilled 1080 Feet Depth Cased 1060 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
30 Inches		0 Feet	70 Feet
20 Inches		70 Feet	1080 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
24'			+1	70
16'			+1	39
12'			39	640
12'			1040	1060

Perforations:
Type perforation Johnson Hi-Cap Screen
Size perforation .060
From 640 feet to 1040 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 70'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 1080 feet to surface feet

9. WATER LEVEL
Static water level 86.7 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Thompson Drilling Co., Inc. Contractor
Address 4185 West Harmon Contractor
Las Vegas, NV 89103

Nevada contractor's license number issued by the State Contractor's Board 4286A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1851

Signed Richard Thompson
By driller performing actual drilling on site or contractor

Date July 21, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627