WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66942
Permit No.
Basin 212

NOTICE OF INTENT NO. 16472

1. OWNER Sammy Armstrong
MAILING ADDRESS 3951 L.V. Blvd. So.
Las Vegas, Nev. 89119

ADDRESS AT WELL LOCATION Vacant

2. LOCATION SE ¼ NW ¼ Sec. 14 T. 19S N/S R. 60 E. Clark County
PERMIT NO. ____ Issued by Water Resources | 125-142-04-006 Parcel No. | Subdivision Name

3. WORK PERFORMED
[XX] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[XX] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[XX] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Popcorn Caliche		0	160	
Sandy Clay		160	200	
Clay & Water	xx	200	215	
Sandy Clay		215	360	
Caliche & Water	xx	360	400	
Clay		400	660	
Caliche & Water	xx	660	700	

Date started 6/30/97, 19
Date completed 7/2/97, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 700 Feet Depth Cased 700 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches		0 Feet	55 Feet
10 5/8 Inches		55 Feet	700 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+1	700

Perforations:
Type perforation Torch
Size perforation 3/16 x 3 row
From 640 feet to 680 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 55
Placement Method: [ ] Pumped [XX] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [ ] Yes [XX] No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 168 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon H. Dimick (Contractor)
Address 5360 Bonita Vista (Contractor)
Las Vegas, Nev. 89129

Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552

Signed V H Dimick
By driller performing actual drilling on site or contractor
Date 7-24-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627