The original WDR for this well has been misplaced

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67042
Permit No.
Basin 212

NOTICE OF INTENT NO. 2987

1. OWNER Aurelio C. Chavez
MAILING ADDRESS
ADDRESS AT WELL LOCATION Serene

2. LOCATION SW ¼ NW ¼ Sec. 24 T. 22 N/S R. 61 E. Clark County
PERMIT NO. Issued by Water Resources | Parcel No. 177-24-201-008 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders		0	160	160
Red Clay & gravel		160	230	70
Red & Blk. Volcanics	X	230	300	70

This duplicate WDR has been OK'd verbally by Dean Goodall
The Original WDR has been misplaced. The information provided here is based on the drillers memory and information from numerous other wells drilled in the same area.

OK by Dean Goodall

JUL 30 1997

Date started 4, 1987
Date completed 8-4, 1989

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35 to 45		

900 CFM @ 250 PSI @ 300 ft.

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)
9 7/8 Inches From 0 Feet To 300 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.156	+1	300

Perforations:
Type perforation Torch
Size perforation 1/4" x 8"
From 240 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 300. feet

9. WATER LEVEL
Static water level 180 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality OK

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Mitchell Enterprises
Contractor
Address 4250 S Arville #262
Contractor
Las Vegas, NV. 89103.
Nevada contractor's license number issued by the State Contractor's Board 27030 (42266 NOW)
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1475
Signed Dean Mitchell
By driller performing actual drilling on site or contractor
Date 7/30/97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627