WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 670431
Permit No.
Basin 212

NOTICE OF INTENT NO. 36662

1. OWNER Timet Henderson Facility
MAILING ADDRESS 8100 Lake Mead Drive Henderson, Nevada
ADDRESS AT WELL LOCATION 8100 Lake Mead Drive Henderson, Nevada

2. LOCATION NE ¼ SW ¼ Sec. 12 T. 22 ~~N~~/S R. 62 E. Clark County
PERMIT NO. Issued by Water Resources
Parcel No. 178-12-501-007 178-13-101-004
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine to Medium		0	15	
Sand with some silt				
Silty Fine Sand with		15	20.5	
some coarse and a				
trace of gravel				
Trace of gravel .2-.5 inch		20.5	22	
Silty fine Sand with coar		22	25	
And Abundant of gravel				
Sandy silt with a		25	30	
trace of coarse and				
gravel (.1-.3 inch				
Dark yellowish				
brown, well Sorted				
Caliche, Volcanic		30	32	
Cobble 3 inch				
Fine to Medium Sand		32	34	
with Abundant gravel				
Fine sandy silt	35.5	34	40	
Dark yellowish				
brown well sorted				
Very Dense				
Clayey Medium		40	50	
to Coarse Sand				
well sorted wet				
to saturated				
Clayey Sand, Fine		50	57	
Sand with some				
gravel, clayey silt				
Brown, dense - End			57.	

Date started June 17, 1997
Date completed June 17, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	N/A	

8. WELL CONSTRUCTION
Depth Drilled 57 Feet Depth Cased 31.5 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12	0	57

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	2.043	.237	0	31.5

Perforations:
Type perforation Schedule 40
Size perforation .020
From 31.5 feet to 57.0 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 23 ft
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 26 feet to 57 feet

9. WATER LEVEL
Static water level 39 ft. feet below land surface
Artesian flow n/a G.P.M. n/a P.S.I.
Water temperature n/a °F Quality n/a

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name John Manley Contractor
Address 3121 S. Park Tempe AZ 85282 Contractor
The Vadc Co.
Nevada contractor's license number issued by the State Contractor's Board 41809
Nevada driller's license number issued by the Division of Water Resources the on-site driller M2070
Signed John Manley By driller performing actual drilling on site or contractor
Date 7-8-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627