

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14011

1. OWNER LAS VEGAS VALLEY WATER DISTRICT ADDRESS AT WELL LOCATION CAMPBELL RESERVOIR
 MAILING ADDRESS 1001 S. VALLEY VIEW BLVD NEAR FLAMINGO RD + US 95
LAS VEGAS, NV 89153

2. LOCATION NE 1/4 NE 1/4 Sec. 19 T. 21 N. R. 62 E. CLARK County
 PERMIT NO. NO-2530 Issued by Water Resources Parcel No. UNKNOWN Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>FILL</u>		<u>0</u>	<u>0.5</u>	<u>0.5</u>
<u>CLAYEY GRAVEL</u>		<u>0.5</u>	<u>8</u>	<u>7.5</u>
<u>SANDY GRAVEL</u>		<u>8</u>	<u>9</u>	<u>1</u>
<u>SANDY CLAY</u>		<u>9</u>	<u>15</u>	<u>6</u>
<u>CLAY</u>		<u>15</u>	<u>20</u>	<u>5</u>
<u>SANDY CLAY</u>		<u>20</u>	<u>24.5</u>	<u>4.5</u>
<u>SILTY CLAY</u>		<u>24.5</u>	<u>55</u>	<u>30.5</u>

8. WELL CONSTRUCTION
 Depth Drilled 55 Feet Depth Cased 51 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 Feet 55 Feet
8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>	<u>1.9</u>	<u>0.237</u>	<u>0</u>	<u>51</u>

Perforations:
 Type perforation FACTORY SLOT
 Size perforation 0.0301
 From 21 feet to 46 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0-15' 15-18' BENTONITE Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 18 feet to 51 feet

RECEIVED
 JAN 10 1995
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 12/21, 1994
 Date completed 12/21, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name THOMAS HIGHT Contractor
 Address 4670 S. POLARIS AVE Contractor
LAS VEGAS NV 89103
 Nevada contractor's license number issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 141869
 Signed Tom Hight
 By driller performing actual drilling on site or contractor
 Date 1/4/95