WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67282
Permit No.
Basin 162

NOTICE OF INTENT NO. 16330

1. OWNER DITTRICH, JERRY & BARBARA
MAILING ADDRESS 6420 S. CONESTOGA PKWY
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION
6420 S CONESTOGA PKWY

2. LOCATION SW 1/4 NW 1/4 Sec. 13 T 21S N/S R 53E E NYE County
PERMIT NO. Issued by Water Resources
44-582-09 Parcel No.
CONESTOGA COUNTRY ESTATES Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY & CALICHE		0	78	78
CALICHE	WB	78	95	17
CLAY		95	112	17
CALICHE	WB	112	123	11
CLAY		123	131	8
CALICHE	WB	131	140	9

AUG 12 1997

Date started 7/16/97 , 19__
Date completed 7/19/97 , 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	16.94	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1/8" X 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 FT
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 58 feet below land surfac
Artesian flow G.P.M. P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Co. Contractor
Address PO BOX 4220 Contractor
PAHRUMP, NV 89041

Nevada contractor's license number issued by the State Contractor's Board 30880

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed Thomas Dan
By driller performing actual drilling on-site or contractor

Date 7/28/97