


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 67301
 Permit No. _____
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16404

1. OWNER THE TERRY GROUP ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____ 4560 E. MCGRAW

2. LOCATION SW 1/4 NE 1/4 Sec. 20 T. 21S N/S R. 54 E. NYE County _____
 PERMIT NO. _____ 45-291-19 GREEN SADDLE RANCH
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Brown clay		4	18	14
Brown clay & caliche		18	37	19
Brown clay		37	56	19
Brown clay & gravel	<input checked="" type="checkbox"/>	56	75	19
Brown clay	<input checked="" type="checkbox"/>	75	91	16
Brown clay & caliche		91	107	16
Brown clay		107	128	21
Brown clay & caliche	<input checked="" type="checkbox"/>	128	160	32

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From To
1.2 Inches 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	160

Perforations:
 Type perforation Torch cut
 Size perforation 1/4" width 8" long
 From 120 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level: 71 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started JULY 29, 1997
 Date completed JULY 29, 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1/4

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name JIM PIKE WELL DRILLING, LLC
 Address P.O. BOX 56 PAHRUMP, NV 89041
 Nevada contractor's license number 17562A issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources 1812
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date AUGUST 4, 1997