PPW-61

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67322
Permit No.
Basin 031

NOTICE OF INTENT NO. 28570

1. OWNER AMAX GOLD INC.
MAILING ADDRESS 600 SOD HOUSE RD.
WINNEMUCCA, NV 89445

ADDRESS AT WELL LOCATION
AMAX SLEEPER MINE

2. LOCATION NE ¼ NW ¼ Sec 21 T 40 (N)S R 35 E HUMBOLDT County
PERMIT NO. 53232 Issued by Water Resources | N/A Parcel No. | N/A Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN ROCK & SOME CLAY		0	45	45
GRAY ROCK		45	130	85
BLACK & GRAY ROCK		130	150	20
GRAY ROCK		150	185	35
GRAY CLAY		185	220	35
GRAY ROCK & CLAY		220	405	185
GRAY & WHITE ROCK		405	415	10
GRAY ROCK & CLAY		415	550	135

Date started NOVEMBER 24, 1995
Date completed NOVEMBER 30, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 550 Feet Depth Cased 530 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
24" Inches	0 Feet	20 Feet
19" Inches	20 Feet	550 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	45.61	.312	0	150
14	45.61	.312	170	230

Perforations:
Type perforation SLOTTED
Size perforation
From 150 feet to 170 feet
From 230 feet to 530 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 550 feet

9. WATER LEVEL
Static water level 165 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 72 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1800

Signed VICTOR HERNANDEZ Victor Hernandez
By driller performing actual drilling on site or contractor
Date JANUARY 4, 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627