WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

14CAD

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67330
Permit No.
Basin 093

NOTICE OF INTENT NO. 33909

1. OWNER RICHARD A. PLACE / LITCHFIELD Builder
MAILING ADDRESS 1245 Goldstone Road
Reno, Nevada 89506

ADDRESS AT WELL LOCATION 1205 Bronze Hill ~~Drive~~ Road
Reno, Nevada 89506

2. LOCATION NE ¼ SW ¼ Sec. 14 T 22N N/S R 19 E Washoe County
PERMIT NO. (Issued by Water Resources) 079-~~480-50~~481-19 (Parcel No.) Antelope Valley Rock Estates #256 (Subdivision Name) Par-4

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	18	17
Decomposed granite		18	22	4
Brown sandy clay		22	36	14
Decomposed granite cement sands		36	40	4
Brown sandy clay		40	62	22
Gray granite		62	152	90
Fracture	X	152	154	2
Gray granite		154	168	14
Fracture granite	X	168	190	22
Gray granite		190	196	6
Fracture	X	196	197	1
Gray granite		197	200	3

RECEIVED 97 JUL 13 AM 10:10 STATE ENGINEER'S OFFICE

Date started 6-30-97, 19
Date completed 7-1-97, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
22		

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8 5/8	Inches	50	Feet	200	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	200

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 foot
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 72 feet below land surface
Artesian flow G.P.M. 22 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed Gary C. Hoeman (By driller performing actual drilling on site or contractor)

Date July 1, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627