WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67345
Permit No.
Basin 037

NOTICE OF INTENT NO. 28660

1. OWNER CONVERSE CONSULTANTS, INC.
MAILING ADDRESS 4840 MILL STREET #S
RENO NV 89502

ADDRESS AT WELL LOCATION OWYHEE HOSPITAL
OWYHEE NV

2. LOCATION SE ¼ NE ¼ Sec. 26 T. 47N N/S R. 52 E ELKO County

PERMIT NO. M/O-468 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND/GRAVEL		0	10	
BASALT		10	50	

RECEIVED
96 SEP 16 PM 12:07
STATE ENGINEERS OFFICE

Date started 8-29, 1996
Date completed 8-29, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 50 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches	0 Feet	50 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2			0	20

Perforations:
Type perforation MACHINE SLOT
Size perforation .010
From 30 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 18
Placement Method: ☐ Pumped ☒ Poured
Gravel Packed: ☒ Yes ☐ No
From 19 feet to 50 feet

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout
X BERTONITE

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BOYLES BROS DRILLING COMPANY (Contractor)
Address 1707 SOUTH 4490 WEST (Contractor)
SALT LAKE CITY UT 84104

Nevada contractor's license number issued by the State Contractor's Board 0005380

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1970

Signed Wilbur L. Franklin (By driller performing actual drilling on site or contractor)
Date 8/9/96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627