



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19156

1. OWNER Brad Allen ADDRESS AT WELL LOCATION 27 Cherry Lane  
 MAILING ADDRESS P.O. Box 231 Yerington Nev 89447  
 2. LOCATION SE 1/4 SW 1/4 Sec 11 T 13 N R 25 E Lyon County  
 PERMIT NO. 04-293-03 Parcel No. Lot 27 Block C Green Acres Sub Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil - Sandy		0	2	2
Fine To Coarse Sand		2	3	1
Brown Clay		3	17	14
Coarse Sand - Gravel		17	30	13
Bluish Clay - Gravel		30	34	4
Coarse Sand - Gravel		34	60	26
Fine To Coarse Sand		60	65	5
Bluish Clay - Gravel		65	70	5
Brown Clay - Gravel		70	76	6
Bluish Clay - Gravel		76	82	6
Coarse Sand - Gravel		82	94	12
Fill		82	94	12
Coarse Sand - Gravel	X	94	124	30
Coarse Sand - Gravel		94	124	30
Red Rock	X	124	129	5

8. WELL CONSTRUCTION  
 Depth Drilled 129 Feet Depth Cased 130 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 129  
20 5/8 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.92</u>	<u>.108</u>	<u>0+1</u>	<u>129</u>

Perforations:  
 Type perforation Sawed  
 Size perforation 3/32 X 3" 6 Rows  
 From 109 feet to 129 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 129 feet

9. WATER LEVEL  
 Static water level 17 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

Date started May 1, 1985  
 Date completed May 4, 1985

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Bailed</u>	<u>40</u>	<u>2</u>	<u>1/2 HR</u>
<u>Air Lift</u>	<u>100</u>	<u>100' AIR Line</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Ogden Bros Drilling Contractor  
 Address 162 N. ByBee Ln Contractor  
Yerington Nev 89447  
 Nevada contractor's license number issued by the State Contractor's Board 15646  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634  
 Signed Ag Ogden  
 By driller performing actual drilling on site or contractor  
 Date 7-7-95