WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67351
Permit No.
Basin 108

I

NOTICE OF INTENT NO. 25792

1. OWNER Keith Kennedy
MAILING ADDRESS 810 Ann Kim Circle, Gardenville, Nev 89410
ADDRESS AT WELL LOCATION 24 E. Mesa DR. Yerington, Nev. 89447

2. LOCATION SW 1/4 SE 1/4 Sec. 29 T. 14 N/S R. 25 E. Lyon County
PERMIT NO. (Issued by Water Resources) 04-083-01 (Parcel No.) Lot 21 Copper Hills Estates (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other m.a.d.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Sandy		0	6	6
Brown Clay - Small Gravel		6	10	4
Coarse Sand - Small Gravel		10	38	28
Coarse Sand - Small Gravel - Few Rock		38	50	12
Coarse Sand - Small Gravel - Clay		50	57	7
Coarse Sand - Small Gravel - Clay Stratas		57	70	13
Coarse Sand - Small Gravel		70	78	8
Coarse Sand - Small Gravel - Clay Stratas		78	82	4
Clay - Coarse Sand - Small Gravel		82	90	8
Coarse Sand - Small Gravel - Clay Stratas		90	100	10
Coarse Sand - Small Gravel	X	100	106	6
Coarse Sand - Small Gravel - Clay Stratas	X	106	110	4
Clay + Coarse Sand		110	125	15
Coarse Sand - Small Gravel	X	125	135	10
Clay + Coarse Sand		135	139	4

Date started 6-17, 1996
Date completed 6-20, 1996

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	20	3'6"	1/2
Air Lift	35	120' air line	1 HR

8. WELL CONSTRUCTION
Depth Drilled 139 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10 5/8	0	139

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	139

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" x 6 Rows
From 119 feet to 139 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 139 feet

9. WATER LEVEL
Static water level 29'6" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. Bee Lane (Contractor)
Yerington, Nev. 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Larry Ogden (By driller performing actual drilling on site or contractor)
Date 7-8-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627