



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25153

1. OWNER Mike + Christie Miller ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 318 apt B N. Whitacre 35 Black Mt Circle
Yerington, NV. 89442 Yerington, NV. 89442
 2. LOCATION NE 1/4 NW 1/4 Sec 11 T. 12 N. R. 25 E. Lyon County _____
 PERMIT NO. 12-221-08 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil - Sandy		0	3	3
Co. Sand + Gravel	X	3	18	15
Clay + Co. Sand - Gravel		18	26	8
Co. Sand - Gravel -				
Few Rock	X	26	70	44
Clay + Coarse Sand		70	75	5
Coarse Sand - Gravel	X	75	100	25
Coarse Sand - Gravel + Rock	X	100	125	25
Coarse Sand - Gravel	X	125	135	10
Clay + Coarse Sand - Gravel		135	140	5
Coarse Sand - Gravel	X	140	159	19

8. WELL CONSTRUCTION
 Depth Drilled 159 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/8 Inches To 0 Feet 159 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1</u>	<u>159</u>

Perforations:
 Type perforation Sawed
 Size perforation 2 1/2" x 3" x 6 Rows
 From 139 feet to 159 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 159 feet

9. WATER LEVEL
 Static water level 9' 6" feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60 °F Quality G-000

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ogden Bros Drilling Contractor
 Address 162 N. B. Bee Ln Contractor
Yerington, NV. 89442
 Nevada contractor's license number issued by the State Contractor's Board 15646
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
 Signed [Signature]
 Date 9-20-96

Date started 9-25-96 19____
 Date completed 9-27-96 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>	<u>90' AIR Line</u>	<u>2 HRS</u>