

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25136

1. OWNER Mark Moore ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 65 Locust Lane 65 Locust Lane
Yerington Nev. 89447 Yerington Nev. 89447
 2. LOCATION NE 1/4 SE 1/4 Sec. 6 T 13 S R 25 E Lyon County
 PERMIT NO. 4-153-10 Parcel No. Valley View Estates Unit #1 Lot 29
 Issued by Water Resources Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC Air Other M40

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Sandy		0	3	3
Hard Pan + Fe ²⁺ Rock		3	6	3
Volcanic Alavina + Rock		6	58	52
Volcanic Alavina + Gravel		58	76	18
Volcanic Alavina + Clay		76	114	38
Volcanic Alavina + Rock	X	114	130	16
Volcanic Alavina + Clay		130	141	11
Volcanic Alavina + Rock	X	141	170	29
Volcanic Alavina + Clay		170	175	5
Volcanic Alavina	X	175	178	3
Clay + Volcanic Alavina + Rock		178	187	9
Volcanic Alavina with Clay Strata	X	187	185	8
Volcanic Alavina + Rock	X	185	199	14

Plugged by Well log 125935

8. WELL CONSTRUCTION
 Depth Drilled 199 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 199 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1</u>	<u>199</u>

 Perforations:
 Type perforation Sawed
 Size perforation 3 3/8" x 6 Rows
 From 159 feet to 199 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 199 feet

7. WELL TEST DATA
 TEST METHOD: Baller Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Baller</u>	<u>20</u>	<u>10</u>	<u>1/2 Hr.</u>

9. WATER LEVEL
 Static water level 118 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ogden Bros Drilling Contractor
 Address 162 N. B. Bee Lane Contractor
Yerington Nev 89447
 Nevada contractor's license number issued by the State Contractor's Board 15646
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
 Signed Larry Ogden Larry Ogden
 By driller performing actual drilling on site or contractor
 Date 3-11-96