WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67354
Permit No.
Basin 037

NOTICE OF INTENT NO. 28660

1. OWNER CONVERSE CONSULTANTS, INC.
MAILING ADDRESS 4840 MILL STREET #S
RENO NV 89502

ADDRESS AT WELL LOCATION OWYHEE HOSPITAL
OWYHEE NV

2. LOCATION SE ¼ NE ¼ Sec. 26 T. 47N N/S R. 52 E. ELKO County
PERMIT NO. 1M10-958 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDS/GRAVEL		0'	10'	
BASALT		10'	45'	

RECEIVED
96 SEP 16 PM 12:07
STATE ENGINEER'S OFFICE

Date started 8-28-96, 19
Date completed 8-28-96, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 45 Feet Depth Cased 45 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	15 Feet
7.75 Inches		15 Feet	45 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4			0	20

Perforations:
Type perforation MACHINE SLOT
Size perforation .010
From 20 feet to 45 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 18
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout
X BERTONITE

Gravel Packed: [X] Yes [ ] No
From 20 feet to 45 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BOYLES BROS DRILLING COMPANY
Contractor
Address 1707SOUTH 4490 WEST
Contractor
SALT LAKE CITY UT 84104
Nevada contractor's license number issued by the State Contractor's Board 0005380
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1970
Signed Wilbur L. Franklin
By driller performing actual drilling on site or contractor
Date 8/9/96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627