

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY


STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 7373

Permit No. _____

Basin 061



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36493

1. OWNER BARRICK GOLDSTRIKE MINES, INC. ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINE SITE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89803

2. LOCATION SE 1/4 SE 1/4 Sec. 19 T. 36 N. S. R. 50 E. EUREKA County
PERMIT NO. M/O 441 A Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED

New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE

Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE

Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BLACK/BROWN/GRAY ROCK		0	80	80
BROWN CLAY		80	130	50
BLACK/BROWN ROCK CLAY		130	140	10
BROWN CLAY		140	150	10
BLACK ROCK		150	165	15
BROWN ROCK		165	285	120
GREY ROCK		285	300	15
BLACK ROCK		300	340	40
BROWN ROCK		340	350	10
BLACK ROCK		350	360	10
BROWN CLAY		360	370	10
GRAY ROCK		370	375	5
BLACK ROCK/GRAVEL		375	500	125
BLACK/GRAY ROCK		500	580	80
BLACK ROCK		580	760	80

plugged by well log 18420

8. WELL CONSTRUCTION

Depth Drilled 760 Feet Depth Cased 403 Feet

HOLE DIAMETER (BIT SIZE)

From	To
14.750 Inches	0 Feet 20 Feet
6.250 Inches	20 Feet 760 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Pt. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1.250	3.00	.191	+1	403

Perforations:

Type perforation SLOTTED

Size perforation .125

From 392' feet to 403 feet

From _____ feet to _____ feet

From _____ feet to _____ feet

From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement

Depth of Seal 100' Cement Grout

Placement Method: Pumped Poured Concrete Grout

Gravel Packed: Yes No

From 253 feet to 410 feet

9. WATER LEVEL

Static water level 384 feet below land surface

Artesian flow _____ G.P.M. _____ P.S.I.

Water temperature _____ °F Quality _____

Date started JUNE 19, 1997

Date completed JUNE 24, 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING Contractor

Address P.O. BOX 5279 Contractor

ELKO, NV 89802

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1800

Signed Victor Hernandez
By driller performing well drilling on site or contractor

Date June 24, 1997