

OFFICE USE ONLY
 Log No. 67386
 Permit No. _____
 Basin. 104

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32135

1. OWNER Bill & Christine Huss ADDRESS AT WELL LOCATION 23 Canyon Dr Carson City NV 89703
 MAILING ADDRESS 23 Canyon Dr Carson City NV 89703
 2. LOCATION S 1/4 SW 1/4 Sec 13 T 15 R 19 E Carson County King Canyon Sub.
 PERMIT NO. 7-131-06 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Cobbles Cemented</u>		<u>0</u>	<u>20</u>	<u>20</u>
<u>Gravels</u>				
<u>Hard Granite</u>		<u>20</u>	<u>110</u>	<u>90</u>
<u>Blue Granite (Very HARD)</u>		<u>110</u>	<u>165</u>	<u>55</u>
<u>Broken DG Granite Hard</u>		<u>165</u>	<u>183</u>	<u>18</u>

8. WELL CONSTRUCTION
 Depth Drilled 183 Feet Depth Cased 183 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 183 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>183</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3 x 3/32
 From 163 feet to 183 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 100
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 180 feet

9. WATER LEVEL
 Static water level 40 feet below land surface
 Artesian flow _____ G.P.M. 18 P.S.I.
 Water temperature 60.4 °F Quality Good

Date started 6-9 1997
 Date completed 6-17 1997

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>18</u>	<u>85</u>	<u>3 HRS</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling
 Address 20 Kit Kat DR Carson City NV 89706
 Nevada contractor's license number 41775 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1995
 Signed Michael Stok
 By driller performing actual drilling on site or contractor
 Date 6-17-97