PW-44

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67426
Permit No.
Basin 031

NOTICE OF INTENT NO. 17060

1. OWNER AMAX GOLD INC.
MAILING ADDRESS 600 SOD HOUSE ROAD
WINNEMUCCA, NV 89445

ADDRESS AT WELL LOCATION
AMAX SLEEPER MINE

2. LOCATION SE ¼ NW ¼ Sec. 21 T 40 (N)S R 35 E HUMBOLDT County

PERMIT NO. 53235 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic DEWATER ☐ Irrigation ☐ Test
☒ Municipal (Industrial) ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ABANTONITE		490	181	
HOLE PLUG		181	50	
NEAT CEMENT		50	0	
ELEVATION OF COLLAR				
DRILLED - 3900'				
T.D. 3190'				
ABANDON 3680'				
PRESENT DEPTH OF WELL	490'			

Date started 06/18/96, 19
Date completed 06/24/96, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 710 Feet Depth Cased 709 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
31 Inches		0 Feet	18 Feet
25 Inches		18 Feet	709 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
26	103.0	.374	0	18
18	58.94	.312	0	709

Perforations:
Type perforation WIRE WRAP / LOUVERED
Size perforation .100 SLOT
From LOUVERED 169 feet to 469 feet
From WIREWRAP 469 feet to 709 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 51 feet to 710 feet

9. WATER LEVEL
Static water level 181 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1939

Signed KEVIN ELLISON Kevin Ellison
(By driller performing actual drilling on site or contractor)

Date 6-24-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627