WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67443
Permit No.
Basin 149

NOTICE OF INTENT NO. 34093

1. OWNER Ted Miller
MAILING ADDRESS 534 N. Bond
Elko NV 89801

ADDRESS AT WELL LOCATION Janie Lane

2. LOCATION NW ¼ NW ¼ Sec. 17 T. 34 N/S R. 55 E. Elko County

PERMIT NO. (Issued by Water Resources) | Map File #375657 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0 | 5 | 5 |
| Clay & gravel | | 5 | 160 | 155 |
| Sand with clay | | 160 | 280 | 120 |
| Layers | X | | | |
| Sand and gravel | | 280 | 320 | 40 |

Date started 8-27, 1996
Date completed 8-30, 1996

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 11 Inches | | 0 Feet | 320 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .188 | 0 | 320 |
| | | | | |

Perforations:
Type perforation Mill Slot
Size perforation
From 272 feet to 312 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 320 feet

9. WATER LEVEL
Static water level 260 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AAA Drilling Co (Contractor)
Address Box 2487 (Contractor)
Elko NV 89801
Nevada contractor's license number issued by the State Contractor's Board 20684
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1783
Signed Larry R Duffield (By driller performing actual drilling on site or contractor)
Date 8-31-96

RECEIVED 1996 SEP 20 AM 11:17 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627