

OFFICE USE ONLY  
 Log No. 67447  
 Permit No. \_\_\_\_\_  
 Basin. 049

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34095

1. OWNER Gravel Mines ADDRESS AT WELL LOCATION PARCEL 2 of File # 319246  
 MAILING ADDRESS 136 W. Adams  
2170 NV

2. LOCATION SE 1/4 SW 1/4 Sec 21 T. 37 N. R. 55 E. 2170 County \_\_\_\_\_  
 PERMIT NO. 319246 Parcel No. \_\_\_\_\_ Subdivision Name Watman  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Top Soil</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>Clay sand</u>		<u>2</u>	<u>87</u>	<u>85</u>
<u>Clay</u>		<u>87</u>	<u>103</u>	<u>16</u>
<u>Clay sand</u>		<u>103</u>	<u>110</u>	<u>7</u>
<u>gravel sand</u>	<u>X</u>	<u>110</u>	<u>125</u>	<u>15</u>
<u>Clay</u>		<u>125</u>	<u>135</u>	<u>10</u>

8. WELL CONSTRUCTION  
 Depth Drilled 135 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
10 Inches 0 Feet 135 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188</u>	<u>0</u>	<u>135</u>

Perforations:  
 Type perforation Full  
 Size perforation \_\_\_\_\_  
 From 110 feet to 130 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 100 ft

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 120 feet to 135 feet

9. WATER LEVEL  
 Static water level 18 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started July 23 1994  
 Date completed July 23 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>22</u>	<u>2</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name AAA Drilling Contractor  
 Address P.O. Box 2487 Contractor  
2170 NV

Nevada contractor's license number issued by the State Contractor's Board 0020684  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438

Signed Shou Bennett  
 By driller performing actual drilling on site or contractor  
 Date July 23 - 94