

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30716

1. OWNER BILL CRANE ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 19 West HAMMAN BLVD Lot 10 Elko Summit Dr
SAGINAW, MT 48602
 2. LOCATION NE 1/4 SW 1/4 Sec 25 T. 34 N/S R. 55 E Elko County _____
 PERMIT NO. _____ Parcel No. Lot 10 - Parcel 4 Subdivision Name ELKO SUMMIT ESTATES
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Loam</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>White Rock SANDSTONE</u>		<u>3</u>	<u>135</u>	<u>132</u>
<u>Fine white sandstone</u>	<u>X</u>	<u>135</u>	<u>140</u>	<u>5</u>
<u>White Rock</u>		<u>140</u>	<u>185</u>	<u>45</u>
<u>Green Rock</u>	<u>X</u>	<u>185</u>	<u>230</u>	<u>45</u>
<u>CLAY</u>		<u>230</u>	<u>240</u>	<u>10</u>

8. WELL CONSTRUCTION
 Depth Drilled 10240 Feet Depth Cased 240 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 240 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.92</u>	<u>1.88</u>	<u>72</u>	<u>240</u>

Perforations:
 Type perforation Slots
 Size perforation 3 x 1/3"
 From 220 feet to 240 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 51 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 51 feet to 240 feet

9. WATER LEVEL
 Static water level 125 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name FERTIG Drilling Co Contractor
 Address P.O. Box 525 Contractor
Elko NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 31904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1504 JI
 Signed Therese Mannerup
 By driller performing actual drilling on site or contractor
 Date July 22 1996

Date started JULY 22 1996
 Date completed July 29 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		<u>4.5</u>