

OFFICE USE ONLY  
Log No. 67469  
Permit No. \_\_\_\_\_  
Basin 102

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31997

1. OWNER Connie Thompson Steel Grease ADDRESS AT WELL LOCATION 1115 5th St  
MAILING ADDRESS 140 E Taylor Reno, NV Silver Springs  
2. LOCATION SW 1/4 NW 1/4 Sec 17 T. 17 S. R. 25 E. Lyon County  
PERMIT NO. 17-146-06 Parcel No. Butte #2 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	4	4
Clay & Sand		4	15	11
Clay		15	55	40
Fine Sand (Bad)	X	55	60	5
Full clay		60	62	2
Full sand		62	108	46
Clay		108	110	2
Sand & Gravel	X	110	120	10

8. WELL CONSTRUCTION  
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)  
From To  
12 Inches 0 Feet 52 Feet  
1 5/8 Inches 0 Feet 120 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1 5/8</u>	<u>13.77</u>	<u>.188</u>	<u>0</u>	<u>120</u>

Perforations:  
Type perforation machined  
Size perforation 1 7/8 x 3  
From 110 feet to 118 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 52  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 52 feet to 120 feet

9. WATER LEVEL  
Static water level 50 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality Good

Date started 8/9 1997  
Date completed 8/13 1997

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>20</u>	<u>0</u>	<u>4</u>	

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Vernon Cannon Jr. Contractor  
Address 4555 Hwy 50 W Contractor  
Silver Springs, NV 89429  
Nevada contractor's license number 23317  
issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1455  
Signed Vernon Cannon Jr.  
By driller performing actual drilling on site or contractor  
Date 8/15/97

RECEIVED  
97 AUG 27 AM 10:48  
STATE ENGINEERING OFFICE