


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 67473
 Permit No. 63135
 Basin 071



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36923

1. OWNER Winnemucca Farms ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3760 S. Railroad Potato Road
Winnemucca, NV 89445

2. LOCATION SW 1/4 NW 1/4 Sec. 6 T 35N N/S R 38E E Humboldt County
 PERMIT NO. 63135T or 63136T Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	11	11
Sand		11	20	9
Sand & gravel		20	24	4
Hardclay w/sand layered		24	57	33
Sand & gravel small cobbles		57	60	3
Sandy clay w/gravel		60	80	20
Sand & gravel		80	85	5
Sandy clay		85	87	2
Sand & gravel w/cobbles		87	98	11
Sand & gravel		98	129	31
See next line		129	190	61
Sand & gravel 10% clay w/boulders				
Sand & gravel		190	200	10
Sandy clay w/gravel streaks		200	270	70
Sand & gravel 10% clay		270	285	15
Clay w/small gravel lumps		285	295	10
Sand & gravel		295	303	8
Sandy clay some gravel		303	310	7
Sand & gravel		310	312	2
Sandy clay		312	355	43
Sand & gravel		355	360	5
Brown clay		360	380	20
Sandy clay w/sand layers		380	420	40

8. WELL CONSTRUCTION
 Depth Drilled 420 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)
 From 30 Inches To 0 Feet 420 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		.250	+2	140
16		.250	220	260
16		.250	320	360

Perforations: ** SEE Log for int. # 36923 C for 6 5/8 casing*
 Type perforation Mill slot & .080 screen
 Size perforation 1/8 x 3

From <u>140</u>	feet to <u>220</u>	<u>Double Mill Slot</u>	feet
From <u>260</u>	feet to <u>320</u>	<u>.080 screen</u>	feet
From <u>360</u>	feet to <u>400</u>	<u>.080 screen</u>	feet
From _____	feet to _____	_____	feet
From _____	feet to _____	_____	feet

Surface Seal: Yes No Seal Type: _____
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100 feet to 420 feet

9. WATER LEVEL
 Static water level 61.48 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Good

Date started 6/14/97, 19____
 Date completed 6/16/97, 19____

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M. <u>1000</u>	<u>135</u>	<u>8 hrs.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc. Contractor
 Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 6-27-97